

Walkthrough Inspection Checklist

Name: _____
 School: _____
 Room or Area: _____ Date Completed: _____
 Signature: _____

Instructions

1. Read the *IAQ Background* and the Background Information for this checklist.
2. Keep the Background Information and make a copy of the checklist for future reference.
3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
4. Return the checklist portion of this document to the IAQ Coordinator.

1. GROUND LEVEL

Yes No N/A

- | | | | |
|--|--------------------------|--------------------------|--------------------------|
| 1a. Ensured that ventilation units operate properly | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1b. Ensured there are no obstructions blocking air intakes | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1c. Checked for nests and droppings near outdoor air intakes | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1d. Determined that dumpsters are located away from doors, windows, and outdoor air intakes | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1e. Checked potential sources of air contaminants near the building (chimneys, stacks, industrial plants, exhaust from nearby buildings) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1f. Ensured that vehicles avoid idling near outdoor air intakes | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1g. Minimized pesticide application | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1h. Ensured that there is proper drainage away from the building (including roof downspouts) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1i. Ensured that sprinklers spray away from the building and outdoor air intakes | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 1j. Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

2. ROOF

While on the roof, consider inspecting the HVAC units (use the Ventilation Checklist).


- | | | | |
|---|--------------------------|--------------------------|--------------------------|
| 2a. Ensured that the roof is in good condition | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2b. Checked for evidence of water ponding | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2c. Checked that ventilation units operate properly (air flows in) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2d. Ensured that exhaust fans operate properly (air flows out) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2e. Ensured that air intakes remain open, even at minimum setting | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2f. Checked for nests and droppings near outdoor air intakes | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2g. Ensured that air from plumbing stacks and exhaust outlets flows away from outdoor air intakes | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

3. ATTIC

- | | | | |
|---|--------------------------|--------------------------|--------------------------|
| 3a. Checked for evidence of roof and plumbing leaks | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3b. Checked for birds and animal nests | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

4. GENERAL CONSIDERATIONS

- | | | | |
|---|--------------------------|--------------------------|--------------------------|
| 4a. Ensured that temperature and humidity are maintained within acceptable ranges | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4b. Ensured that no obstructions exist in supply and exhaust vents | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4c. Checked for odors | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4d. Checked for signs of mold and mildew growth | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |



4. GENERAL CONSIDERATIONS (continued)

- | | Yes | No | N/A |
|--|--------------------------|--------------------------|--------------------------|
| 4e. Checked for signs of water damage | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4f. Checked for evidence of pests and obvious food sources | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4g. Noted and reviewed all concerns from school occupants | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

5. BATHROOMS AND GENERAL PLUMBING

- | | | | |
|--|--------------------------|--------------------------|--------------------------|
| 5a. Ensured that bathrooms and restrooms have operating exhaust fans | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5b. Ensured proper drain trap maintenance: | | | |
| Water is poured down floor drains once per week (approx. 1 quart of water) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Water is poured into sinks at least once per week (about 2 cups of water) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Toilets are flushed at least once per week | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

6. MAINTENANCE SUPPLIES

- | | | | |
|--|--------------------------|--------------------------|--------------------------|
| 6a. Ensured that chemicals are used only with adequate ventilation and when building is unoccupied | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6b. Ensured that vents in chemical and trash storage areas are operating properly | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6c. Ensured that portable fuel containers are properly closed | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6d. Ensured that power equipment, like snowblowers and lawn mowers, have been serviced and maintained according to manufacturers' guidelines | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

7. COMBUSTION APPLIANCES

- | | | | |
|--|--------------------------|--------------------------|--------------------------|
| 7a. Checked for combustion gas and fuel odors | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7b. Ensured that combustion appliances have flues or exhaust hoods | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7c. Checked for leaks, disconnections, and deterioration | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7d. Ensured there is no soot on inside or outside of flue components | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

8. OTHER

- | | | | |
|--|--------------------------|--------------------------|--------------------------|
| 8a. Checked for peeling and flaking paint (if the building was built before 1980, this could be a lead hazard) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8b. Determined date of last radon test | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

NOTES